



NOTIFIED BODY No. 1293

## CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 - CPR - 0703

In compliance with the Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Intelligent analogue addressable electrical mains switching output module with built-in isolator SensolRIS MOUT-240, Belinda MOUT-240, Erida MOUT-240, Marl MOUT-240, Smoke sense MOUT-240, SensolRIS MOUT-240 IP55, Expera Oi Mains IP55, MAGPRO-R

For specifications see Annex to this certificate placed on the market under the name or trade mark of

Teletek Electronics JSC 14A Srebarna Str., 1407 Sofia, Bulgaria

and produced in the manufacturing plant

Teletek Electronics JSC 14A Srebarna Str., 1407 Sofia, Bulgaria

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

EN 54-18:2005

EN 54-18:2005/AC:2007

EN 54-17:2005

EN 54-17:2005/AC:2007

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

## constancy of performance of the construction product.

This certificate was first issued on October 28th, 2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Nová Dubnica, October 28th, 2020

053751

Marek Hudák Director NB

EVPÚ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk Page 1 / 2 FCO 425-13 Rev.1

## Annex to Certificate No. 1293 - CPR - 0703 from October 28th, 2020

**Technical Specifications** 

SensoIRIS MOUT-240 (derived variants Belinda MOUT-240, Erida MOUT-240,

Marl MOUT-240, Smoke sense MOUT-240, SensolRIS MOUT-240 IP55, Expera Oi Mains IP55, MAGPRO-R) is an electrical mains switching relay output control module designed for application in addressable fire alarm systems, supporting communication protocol.

SensoIRIS MOUT-240, Belinda MOUT-240, Erida MOUT-240, Marl MOUT-240, Smoke sense MOUT-240 is mounted in a separate small plastic box suitable for wall mounting, with transparent cover for visual inspection.

SensoIRIS MOUT-240 IP55, Expera Oi Mains IP55, MAGPRO-R is mounted in a separate plastic box suitable for wall mounting and IP55 protection.

The device works with Operating voltage (16 - 32) VDC.

| Essential characteristics                                     | Harmonised technical specification         |  |             |
|---|--|--|-------------|
|   | EN 54-18:2005<br>EN 54-18:2005/<br>AC:2007 | EN 54-17:2005<br>EN 54-17:2005/<br>AC:2007 | Performance |
| Response delay (response time)                                | cl. 5.2                                    |  | Pass        |
| Performance under fire conditions                             | cl. 5.1.4                                  | cl. 5.2                                    | Pass        |
| Operational reliability                                       | cl. 5.1.4                                  | cl. 4                                      | Pass        |
| Durability of operational reliability: temperature resistance | cl. 5.3, 5.4                               | cl. 5.4, 5.5                               | Pass        |
| Durability of operational reliability: vibration resistance   | cl. 5.8 to 5.11                            | cl. 5.9 to 5.12                            | Pass        |
| Durability of operational reliability: humidity resistance    | cl. 5.5, 5.6                               | cl. 5.6, 5.7                               | Pass        |
| Durability of operational reliability: corrosion resistance   | cl. 5.7                                    | cl. 5.8                                    | Pass        |
| Durability of operational reliability: electrical stability   | cl. 5.2, 5.12                              | cl. 5.3, 5.13                              | Pass        |

Service Servic

Nová Dubnica, October 28th, 2020

Marek Hudák Director NB

EVPÜ a.s., Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk Page 2 / 2 FCO 425-13 Rev.1