

# Certificate

of  
Continued Compliance

No: 13229058/AA/04

In compliance with the procedure specified in the Alarm Components Scheme, Telefication declares that the stated alarm equipment complies with the Technical standards and specifications as listed in Annex 2 of this certificate. This certificate relates to an ISO/IEC 17067 scheme type 5 registration including biennial factory inspection and yearly market surveillance.

Product description: **PIR Detector with 20m/11 curtained & 60/1 curtain with NC relay**

Trademark: **Interlogix**

Type designation: **VE735**

Serial No: **N/A**

Hardware / Software version: **0792R1 / V1.5**

Variants: **See Annex 3**

Manufacturer: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003DH Weert**

Country: **Netherlands**

This certificate is granted to:

Name: **UTC Fire & Security B.V.**

Address: **Kelvinstraat 7**

City: **6003DH Weert**

Country: **Netherlands**

Expiry date: **19 July 2024**

This certificate has THREE Annexes.

Zevenaar, 20 July 2020



Jan Willem Verwoert  
Project Manager





## Remarks and observations

The following conditions are applicable:

Security grade: 2

Environmental class: II

Equipment class: Fixed

This equipment can be applied in EN 50131-1 compliant systems up to and including security grade 2.





**The product as described in this certificate includes the following type designations:**

- Product description: PIR Detector with 20m/11 curtaild & 60/1 curtain with NC relay  
- Trademark: Interlogix  
- Type designation: VE735  
- Hardware version: 0792R1  
- Software version: V1.5  
- Serial number: N/A

- Product description: PIR Detector with 20m/11 curtaild & 60/1 curtain with CO relay  
- Trademark: Interlogix  
- Type designation: VE736  
- Hardware version: 0792R1  
- Software version: V1.5  
- Serial number: N/A